

Meeting on August 14, 2007

1. **2006 IBC section 508.3.2 & Table 508.2, 406- Non separated use buildings. Please review and bring comment as it appears that buildings designed and in compliance with non separated use requirements require no separation of any type between such buildings and attached or connected parking garages? Is it time to keep BS-ing architects or do we need an immediate code change proposal?**

Jody is going to propose an amendment to the code that covers this situation and requires a minimum of 1 hour separation between the occupancies.

2. **How many circuits are required in a residential kitchen built under the 2006 IRC?**

The answer that was agreed upon was three: two small appliance circuits and another for the lights and other receptacles. I am looking at section E.3603.2 of the IRC and it may suggest something different. This may be a discussion for another meeting.

3. **Dryer vents? What is every body doing and is there a code change needed?**

It was decided that we should leave it alone for now.

4. **ICC Evaluation reports? What are you doing?**

It was reported that the Legacy Reports are no longer applicable. This is according to a letter sent out from ICC by John Nosse.

5. **Cultured Stone. Do we really care? Are you requiring ICC Evaluation Reports?**

Probably should but most of the jurisdiction's representatives present were not requiring reports.