

Statewide amendments to the IMC

1. IMC, Section 403 a new section 403.8 is added as follows: “Retrospective effect. Removal, alteration, or abandonment shall not be required, and continued use and maintenance shall be allowed, for a ventilation system within an existing installation that complies with the requirements of this Section 403 regardless of whether the ventilation system satisfied the minimum ventilation rate requirements of prior law.”
2. IMC Section 1101.10 is deleted

Insert before page 35

Insert before page 89